

CONNECTIONS

Sensor Type	Serial coding	Connections			
		A	B	C	D
PT100	Txxxx	white	white	red	red

Note - Erratic temperature readings will be recorded if the 4 wire connections A, B, C and D are not secure.



Temp POD

Item
10G20

CALIBRATION

None

WEB

On www.general-alert.com, login using Username and Password.

Options:

- Name the POD (Temp. Tank A, Cooling 25 etc.)
- Set Alarm levels (above or below specific temperatures)
- Establish times of day and days of week for Alarm settings
- Enable Daily Data Feed (for online graphing and recording)
- Establish Users to be notified on POD Alerts
- Obtain instant live Status Report from POD

MOBILE

To access features you need to be a listed User on a General Alert Account.

Features:

Receive Alerts

'Temp. Tank A (T0002224)
Alert: Temp = 28.2 deg. on
Alarm 2 (Normal = 28.1 deg.)

Cancel Alarm (while the problem is being sorted)

2224.0.2

Request Status Report for live data

2224.6

Receive Status Report

'Temp. Tank A (T0002224).
Reading = 20.6 at Aug 08
2010 16.45 (local time)

PO Box 103, Safron Walden, CB11 3GD, UK
T: +44 1799 550837, e: info@general-alert.com
W: www.general-alert.com